

Mayor
Shari L. Buck

Acting City Manager
Maryann Ustick



Council Members
William I. Robinson
Robert L. Eliason
Anita G. Wood
Richard J. Cherchio

Utilities Department – David H. Bereskin, P.E., Director

2829 Fort Sumter Dr. • North Las Vegas, Nevada 89030

Telephone: (702) 633-1275 • Fax: (702) 649-9784 • TDD (800) 326-6868

www.cityofnorthlasvegas.com

ADDENDUM NO. 3
BID NO. 1375
LOSEE SEWER LINE – PHASE 2A ALEXANDER TO MENDENHALL
ISSUE DATE: 9/21/10

THE BIDDER SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM UNDER THE FIRST ADDENDUM LINE ON THE FIRST PAGE OF THE BID PROPOSAL.

The following are changes and/or clarifications to the contract documents, specifications and drawings for the above referenced project.

1. ADDENDUM 1 COMMENT 1 CLAIFICATION

Comment 1

Who will pay for night time inspections from the City of North Las Vegas staff?

Response 1

For all work performed during the normal night working hours (9 PM to 6 AM), the City will be responsible for payment of night time inspections. The scope of work for night construction will include, but not be limited to paving on Craig Road and Losee Road as well as the City's acceptance of Bid Alternate #1 for night time work. For the Base Bid payment of night inspections will be the responsibility of the Contractor.

CLARIFICATION

If Base Bid (DAY TIME WORK SCHEDULE) is awarded then the Contractor will be responsible for all night inspection costs incurred. If Additive Alternate Bid Number # 1(NIGHT TIME WORK SCHEDULE) the Utility Inspections will be the responsibility of the City and the Public Works Department Construction Services Inspections for night work will be the responsibility of the Contractor.

For inspection Rates refer to section 7.2.11 "Working Hours".

**ADDENDUM NO. 3
BID NO. 1375
LOSEE SEWER LINE – PHASE 2A ALEXANDER TO MENDENHALL
ISSUE DATE: 9/21/10**

Comment 2

What are the dollar amounts we are to insert for Bid Item 109.1" CONSTRUCTION CONFLICTS" on both the DAY TIME WORK SCHEDULE Bid Items and the NIGHT TIME WORK SCHEDULE Bid Items.

Response 2

Line Item 109.01 is to be deleted from the bid schedule for both the DAY TIME WORK SCHEDULE and NIGHT TIME WORK SCHEDULE. Revised sheets BP-2 and BP-3 have been included with this addendum.

Comment 3

C 905 pipe is called out on sheets U-03 and U-04 but is not specific on the class of pipe.

Response 3

The C905 pipe is to meet or exceed class DR 32.5.



CURT KROEKER, P.E.
Associate Engineer/Utilities