

**SECTION 630**

**SANITARY SEWERS**

**DESCRIPTION**

**630.01.02 CONFORMANCE WITH LINE AND GRADE**

*Add the following to this subsection:*

All the sanitary sewer work shall be in accordance with the "Design and Construction of Standards for Wastewater Collection System", latest edition.

**MATERIALS**

**630.02.01 GENERAL**

*Add the following to this subsection*

(a) All materials for the construction of sanitary sewer work shall be in accordance with the "Design and Construction Standards for Wastewater Collection System", latest edition.

(b) PVC sewer pipe shall be in accordance with ASTM F679, Standard Specification for Poly Vinyl Chloride (PVC) Large-Diameter Plastic Gravity Sewer Pipe and Fittings. The minimum pipe stiffness shall be 46 psi as required per contract drawings.

(c) C905 pipe shall be installed per Uniform Design and Construction Standards for Water Distribution Systems (UDACS) standards.

**MEASUREMENT**

**630.04.01 MEASUREMENT**

**630.04.01 MEASUREMENT**

*Add the following to this subsection:*

The Method of Measurement for "Sanitary Sewer lateral" shall be per Each

**BASIS OF PAYMENT**

**630.05.01 PAYMENT**

*Add the following to this subsection:*

The contract unit price bid shall be full compensation for furnishing the materials, equipment, tools, labor, excavation, bedding, backfilling, shoring, connectors, wyes, concrete encasement and all incidentals in accordance with specifications. For any modifications or repair required to the laterals or wye connections. Contractor shall maintain the constant flow of sewer. Materials, equipment and labor for this work shall be incidental to this bid item

The repair of any damaged lateral and connections shall be considered incidental to the finished construction of the 8-inch waterline. As such there will be no separate payment for this material and should be included in the costs of bid items 629.01.

Pay Item  
4" C905 Sanitary Sewer Lateral

Pay Unit  
Each