

Mayor
Michael L. Montandon

City Manager
Gregory E. Rose

Council Members
William E. Robinson
Stephanie S. Smith
Shari Buck
Robert L. Eliason

Utilities Department - Technical Services Division
2829 Fort Sumter Dr. • North Las Vegas, Nevada 89030
Telephone: (702) 633-2676 • Fax: (702) 649-399-0383 • TDD: (800) 326-6868
www.cityofnorthlasvegas.com

ADDENDUM NO. 1
BID NO. 1319
WATER SECURITY SYSTEMS WELL IMPROVEMENTS
ISSUE DATE: 3/23/09

THE BIDDER SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM UNDER THE FIRST ADDENDUM LINE ON THE FIRST PAGE SECTION BID PROPOSAL.

The following are changes and/or clarifications to the contract documents, specifications and drawings for the above referenced project.

1. CONTRACT DOCUMENTS

A. SECTION 09970 COATINGS

3.04 APPLICATION, GENERAL Section A

Reads

- A. Coating and paint application shall conform to the requirements of the Steel Structures Painting Council Paint Application Specification SSPC-PA1, latest revision, for "Shop, Filed and Maintenance Painting", the American Water Works Association, the City of North Las Vegas, and the manufacturer of the coating and paint materials printed literature and as specified herein. The City of North Las Vegas does not accept coatings to be applied by rollers. All coatings shall be applied by sprayers as described in these specifications.

Revised to Read (The last two sentences in the above section have been deleted)

- A. Coating and paint application shall conform to the requirements of the Steel Structures Painting Council Paint Application Specification SSPC-PA1, latest revision, for "Shop, Filed and Maintenance Painting", the American Water Works Association, the City of North Las Vegas, and the manufacturer of the coating and paint materials printed literature and as specified herein.

CURT KROEKER, P.E.
Associate Engineer/Utilities

KAREN L. STORMS, CMC
City Clerk