

Mayor  
**Shari L. Buck**

City Manager  
**Gregory E. Rose**

Council Members  
**William E. Robinson**  
**Robert L. Eliason**  
**Anita G. Wood**  
**Richard J. Cherchio**

**Utilities Department - Technical Services Division**  
2829 Fort Sumter Dr. • North Las Vegas, Nevada 89030  
Telephone: (702) 633-2676 • Fax: (702)649-9784  
[www.cityofnorthlasvegas.com](http://www.cityofnorthlasvegas.com)

**ADDENDUM NO. 2**  
**BID NO. 1351**  
**EAST RESERVOIRS RECOATING**  
**ISSUE DATE: 9/16/09**

THE BIDDER SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM UNDER THE FIRST ADDENDUM LINE ON THE FIRST PAGE OF THE BID PROPOSAL.

---

The following are changes and/or clarifications to the contract documents, specifications and drawings for the above referenced project.

**Comment 1**

Can steel grit be used as a blast material?

**Response 1**

Please refer to Section 01330 1.01 REQUIRED SHOP DRAWINGS Paragraph E.

- E. The Contractor shall submit data certifying the chemical composition of the blast abrasive to be used. The blast abrasive shall not contain levels of Barium, Beryllium, Cadmium, Chromium, Mercury, Nickel, Lead or Copper in concentrations greater than that allowed by RCRA. The maximum Selenium concentration allowed for all blast abrasives used shall be .05 mg/L. The blast abrasive shall be tested according to the RCRA's TCLFP metals Leachate Test.

Also for clarification in Section 09970, Section 3.02 SURFACE PREPARATION, GENERAL, Paragraph M

- M. Abrasive used in blast cleaning operations shall be new, washed, graded and free of contaminants which would interfere with adhesion of coatings and points and shall not be reused unless specifically approved by the City's designated representative.

The City Representative does not approve of reused material.

---

CURT KROEKER, P.E.  
Associate. Engineer/Utilities